

AeroRaq Engineering Inc
8511 Davis Lake Parkway, Suite C6-205 Charlotte NC 28269
Phone: (704) 469-8463
hakeembailey@aeroraq.com
www.aeroraq.com

ADDENDUM 3:

Project: Guilford County Schools; Northeast High School Bond Renovation

Address: 6700 McLeansville Rd. McLeansville NC 27301

Date: 04/15/24

1. All vertical unit ventilators shall have hot gas reheat for use in the dehumidification cycle.
2. Contractors will disregard section 01 77 00 of the closeout procedures, Part 3.1 Final Cleaning.
3. Re-Bid date and time is set for April 24th, 2024 at 1:30pm.

Regards,

Hakeem R. Bailey, P.E.

Principal Project Manager,

8511 Davis Lake Parkway, Suite C6-205 Charlotte NC 28269

Office: (704) 469 8463

hakeembailey@aeroraq.com