

Cooling Tower Replacement Hairston Middle School

Guilford County Schools

Addenda #3

January 10th, 2023

1. Bid opening for this project will be at **2:00 PM on Thursday January 12th, 2023, in Room 100, 501 W. Washington Street, Greensboro, NC 27401**. The contractors are to mail or hand deliver, including MWBE required documentation. Mail to Tracy Nance. If the contractor wishes he may drop off a hard copy of the bid or attend the bid opening in person.
2. The contractor is to install isolation valves on the return water to the tower to allow balancing. Valves are not required on the basin connection piping. Overflow piping and drain piping, similar to the existing, is to be included.
3. All Contractors submitting proposals shall incorporate the items in this Addendum, and all other addenda into their proposals, and acknowledge receipt of the Addenda on their bid proposal forms.