


| | |
|---|---|
|  | <p align="center">GUILFORD COUNTY SCHOOLS Invitation for Bid Addendum #3 02/12/2024 Purchasing Department 501 W. Washington Street Greensboro, NC 27401</p> |
| Direct all inquiries to: | Invitation for Bid: 6619 |
| Velicia Moore | Proposal due date: March 8, 2024 |
| gaddyv@gcsnc.com 336.370.3240 | Commodity: Playground Equipment Installation |

NOTICE TO BIDDERS

Please be advised that this document serves as Addendum #3 to IFB 6619 – Playground Equipment Installation for the 2022 Bond. The following is a statement from Guilford County Schools (GCS) and questions asked by vendors. The answers were provided by GCS, please see below:

Statement

Please include with your proposal the following specifications:

- 1) Bonded rubber surfacing with
 - a. Minimum of 3” compacted stone base @ 90% or greater compaction.
 - b. Rubber thickness corresponding with structure fall height.
 - c. Rolled/tucked edges around perimeter or playground area.
 - d. Must include shipping and installation costs.
- 2) A hip shade over entire play unit with embedded posts. An integrated shade will be considered. Must include shipping and installation costs.
- 3) The bid date has been extended to March 8, 2024.

We understand there will be an increase in the original cost due to this change.

Questions

- Q1. Will this surfacing be required to be IPEMA certified?**
A1. Yes.
- Q2. With the new information, please consider another extension to the due date?**
A2. The bid date has been extended to March 8, 2024.