



**GUILFORD COUNTY SCHOOLS**  
**Invitation for Bid**  
**Addendum #1**  
**04/19/2024**  
Purchasing Department  
501 W. Washington Street  
Greensboro, NC 27401

|   |   |
|---|---|
| <b>Direct all inquiries to:</b>                                     | <b>Invitation for Bid: 6649</b>                               |
| Velicia Moore   | <b>Proposal due date: April 22, 2024</b>                      |
| <a href="mailto:gaddyv@gcsnc.com">gaddyv@gcsnc.com</a> 336.370.3240 | <b>Commodity: Interior Door Locks – High Point Central HS</b> |

**NOTICE TO BIDDERS**

Please be advised that this document serves as Addendum #1 to Q6649 – Interior Door Locks for the 2022 Bond. The following questions were asked by vendors. The answers were provided by GCS, please see below:

Questions

**Q1. Can you please confirm the cylinder type for the item below?**

Schlage D125 Mortise Cylinder

626 - Keyed from factory

**Is it LFIC or Conventional? Primus or Everest?**

A1. Conventional. Everest.

**Q2. Do the doors already have Mortise locks on them now?**

A2. Yes.

**Q3. Are you looking to change from Classroom function to Storeroom function?**

A2. Yes.

**Q4. Are the locks removable core?**

A2. No.